energysafe VICTORIA Creating a safer state with electricity and gas

Gas Information Sheet No. 03

Fire resistant boards

According to the suppliers, the following materials comply with the requirements of AS 5601 – Gas Installations, Appendix C. Other materials may also comply, check with your supplier.

Proprietary name of material	Minimum thickness required	Supplier
Bellis Board Firemaster 550* Supalux Promina Promatect H	9 mm 10 mm 9 mm 9 mm 12 mm	Bellis Australia Pty Ltd 2/11 Havelock Road Bayswater VIC 3153 Phone (03) 9720 5100
Bellis Board (Available in cut sheets) (1200 x 600 mm)	9 mm	Bradflo 7 Rushdale Street Knoxfield VIC 3180 Phone (03) 9764 9656
Firemaster 550*	10 mm	Morgan Thermal Ceramics Unit 3/4 111-113 William Angliss Drive North Laverton VIC 3026 Phone (03) 9360 0355
Orbit FR	9 mm	Trafalgar Products Phone 1800 888 714 For the closest distribution for both Supalux and Orbit FR
Promina Promatect H	12 mm 12 mm	Cement Sheet Products 1029 Western Highway Deer Park VIC 3023 Phone (03) 9361 9999
Laminex Metaline Splashback Where the installation is behind a gas or electric hot plate, refer to the "Metaline - Fabrication Manual" for minimum clearance details and mineral board installation. (Installation directly onto brickwork or cement blocks does not require the installation of mineral board).	4mm + Mineral Board = total 13 mm	The Laminex Group Pty Ltd 90-94 Tram Road Doncaster VIC 3108 Phone (03) 9848 4811
FRB – Fire Retardant Board (2400 x 1200 mm)	9 mm	CFM Fans Pty Ltd 56 Tarnard Drive Braeside VIC 3195 Phone (03) 9580 7790 sales@cfmfans.com.au

* Not acceptable for use where the board is required to support an appliance.

If further information is required, please phone the Gas Safety Technical Information Line on 1800 652 563.